

Navrh otopnych teles

=====

Akce : PRISTAVBA PAVILONU 2. ZS BEROUN, ul. Preislerova

Datum : 10. 6.2017

Teplota topne vody - privodni : 70.0 oC

vratne : 55.0 oC

Procento vykonu pro navrh teles : 100.0

Vypis pro okruh c. 1

Mistnost		Soustava	Otopne teleso	vodni tepelny		
cislo	popis			delka	objem	vykon
oC	oC/oC	teplota		mm	dm3	W
		--				----
02	chodba	15 70/55		1200	3.2	957
02	chodba	15 70/55		1000	5.1	1037
02	chodba	15 70/55		800	4.1	830
03	recepce	20 70/55		1200	6.1	1070
04	satna	15 70/55		1400	3.8	1116
04	satna	15 70/55		1400	3.8	1116
04	satna	15 70/55		1400	3.8	1116
04	satna	15 70/55		1400	3.8	1116
04	satna	15 70/55		1400	3.8	1116
04	satna	15 70/55		1400	3.8	1116
04	satna	15 70/55		1400	3.8	1116
04	satna	15 70/55		1100	3.0	877
10	technicka mistnt	15 70/55		900	2.4	718
11	kabinet	20 70/55		1200	6.1	1070
12	ucebna	20 70/55		1200	3.2	825
12	ucebna	20 70/55		1200	3.2	825
12	ucebna	20 70/55		1200	3.2	825
13	chodba	15 70/55		900	2.4	718
13	chodba	15 70/55		900	2.4	718
101	schodiste	15 70/55		1200	6.1	1244
103	chodba	15 70/55		700	3.6	726
103	chodba	15 70/55		1000	5.1	1037
103	chodba	15 70/55		1000	5.1	1037
103	chodba	15 70/55		1100	3.0	877
104	ucebna fyziky	20 70/55		1400	7.1	1249
104	ucebna fyziky	20 70/55		1400	7.1	1249
105	kabinet	20 70/55		1200	3.2	825

106	ucebna zemepisu	20	70/55	1600	4.3	1099
106	ucebna zemepisu	20	70/55	1600	4.3	1099
107	ucebna jazyku	20	70/55	1600	4.3	1099
107	ucebna jazyku	20	70/55	1600	4.3	1099
108	kabinet	20	70/55	1600	4.3	1099
110	WC chlapci	15	70/55	600	1.6	479
113	WC divky	15	70/55	800	2.2	638
114	uklid	15	70/55	700	1.9	335
115	WC ucitele	22	70/55	700	1.9	451
115	WC ucitele	22	70/55	700	1.9	451
116	hygienicka kab.	24	70/55	500	4.2	608
117	chodba	15	70/55	1400	7.4	1795
117	chodba	15	70/55	1400	7.4	1795
117	chodba	15	70/55	1400	7.4	1795
117	chodba	15	70/55	1400	7.4	1795
201	chodba	15	70/55	1400	7.1	1452
203	chodba	15	70/55	700	3.6	726
203	chodba	15	70/55	700	3.6	726
203	chodba	15	70/55	1100	5.6	1141
203	chodba	15	70/55	1100	5.6	1141
203	chodba	15	70/55	1100	5.6	1141
204	ucebna prirodop.	20	70/55	1600	8.2	1427
204	ucebna prirodop.	20	70/55	1600	8.2	1427
205	kabinet	20	70/55	1600	4.3	1099
206	ucebna jazyku	20	70/55	1400	7.1	1249
206	ucebna jazyku	20	70/55	1400	7.1	1249
207	ucebna jazyku	20	70/55	1400	7.1	1249
207	ucebna jazyku	20	70/55	1400	7.1	1249
208	kabinet	20	70/55	900	2.4	619
208	kabinet	20	70/55	900	2.4	619
210	WC chlapci	15	70/55	700	1.9	558
213	WC divky	15	70/55	900	2.4	718
214	uklid	15	70/55	700	1.9	335
215	WC ucitele	22	70/55	600	3.1	502
215	WC ucitele	22	70/55	600	3.1	502
216	hygienicka kab.	24	70/55	500	4.2	608

Celkem okruh c.

61863 W